


DETAIL 1
MINIMUM ESB SPACING REQUIREMENTS FOR UP TO 2 NO. ESB DUCTS IN ANY LAYER

DETAIL 2
MINIMUM ESB SPACING REQUIREMENTS FOR MORE THAN 2 NO. ESB DUCTS IN ANY LAYER



DETAIL 3
CROSS SECTION OF STANDARD FOOTPATH INDICATING REQUIRED TRENCH DEPTH & UTILITY DUCTS SPACING REQUIREMENTS. MARKER TAPES TO BE LAID FOR EACH DUCT AT MINIMUM DEPTH OF 300MM

GENERAL NOTES

ANY DISCREPANCIES OR OMISSIONS TO BE REPORTED TO JAK CONSULTING ENGINEERS IMMEDIATELY.


DO NOT SCALE - WORK FROM FIGURED DIMENSIONS ONLY.

THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL CIVIL ENGINEERS, STRUCTURAL ENGINEERS, ARCHITECTS & ALL OTHER RELEVANT DRAWINGS & SPECIFICATIONS RELATING TO THE PROJECT.

ALL DIMENSIONS TO BE CONFIRMED ON SITE.

THIS DRAWING IS THE PROPERTY OF JAK CONSULTING ENGINEERS AND IT OR ITS CONTENTS CANNOT BE COPIED, REPRODUCED OR OTHERWISE USED WITHOUT THE PERMISSION & CONSENT OF JAK CONSULTING ENGINEERS. ©

- LEGEND**
- esb — PROPOSED ESB DUCT ROUTE.
 - EXISTING ESB MV/LV 125MM RED BAND DUCT ROUTE.
 - - - EXISTING 10KV OVERHEAD ESB LINE TO BE DIVERTED
 - - - PROPOSE PUBLIC LIGHTING DUCT (100MM)
- [S] ESB KIOSK
 - [J] ESB JOINT LOCATION
 - [X] ESB MANHOLE
 - [O] ESB LINE POLE
 - [●] EXISTING POLE LOCATION
 - [●] POLE TO BE REMOVED UPON DIVERSION
- NOTES**
- DRAWINGS TO BE READ IN CONJUNCTION WITH EXISTING ESB SERVICES DRAWING.



ENSURE THAT TRENCH IS DEEPENED AT THIS POSITION AND CABLE IS SUPPORTED ALL ROUND SO IT DOES NOT TIGHTEN FURTHER DURING BACKFILLING.

DETAIL 2
ESB OVERHEAD LINE DROP TO UNDERGROUND DUCT

REV	Description	DRN	APP	Date
I3	INFORMATION	NM	MO	01-11-2019
I2	INFORMATION (BACKGROUND UPDATED)	NM	MO	29-10-2019
I1	INFORMATION	NM	MO	21-10-2019

JAK
Consulting Engineers

Mechanical, Electrical & Sustainability Consultants
 DCC Centre,
 12 Camden Row, Dublin 8,
 Ireland

Ph: +353(1)479 0500
 E: info@jak.ie
 www.jak.ie

PROJECT CLIENT:
SEAMOUNT DEVELOPMENT MALAHIDE BALLYMORE

ARCHITECT:
REDDY ARCHITECTS

DRAWING TITLE:
ESB SERVICE LAYOUT SITE PLAN

DRAWING REFERENCE: J546(6)-J02	DRAWING/PROJECT STATUS: INFORMATION	REVISION REF: I3
FILENAME: J546(6)-J02.DWG	DATE: 03/07/19	SCALE @ A1: 1/500